

RMG 14A

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 94784
 Permit No. _____
 Basin 37 B
 NOTICE OF INTENT NO. 46691

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER Round Mountain Gold ADDRESS AT WELL LOCATION #1 Smokey Valley Mine Rd Round Mountain NV. 89045
 MAILING ADDRESS P.O. Box 480 Round Mountain NV. 89045
 2. LOCATION SE 1/4 NW 1/4 Sec 32 T. 40 N. R. 44 E. NVE County _____
 PERMIT NO. GHA IWD PC 8-6-04 Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other APCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	5	
Red volcanic Rock		5	60	
Some Clay, Red		60	65	
Volcanic Rock				
Red Volcanic Rock		65	120	
Grey to Red Volcanic, Quartz		120	145	
SAME		145	400	
Clay Brown		400	405	
Grey & Red conglomerate		405	405	
Volcanic Rock				
Volcanic With Brown Clay lenses		455	470	
Rock White, orange, grey and Red		470	525	
Grey and Red with Brown clay		525	535	
Mostly Clay		545	565	
Rock Grey and Red		565	575	
Brown Clay		575	600	
Light Brown clay		600	605	
Rock		605	610	
White to pink clay		610	620	
Rock purple to pink		625	625	
Clay white to Red		625	640	
Rock Red to purple		640	645	
Clay pink to white		645	670	

8. 670 WELL CONSTRUCTION 670
 Depth Drilled 540 Feet Depth Cased 540 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 20 Feet
9 5/8 Inches 20 Feet 120 Feet
7 5/8 Inches 120 Feet 670 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 80 pvc</u>	<u>0</u>	<u>470</u>

Perforations:
 Type perforation slot
 Size perforation .125
 From 470 feet to 670 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 / chips 50 to 460
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 460 feet to 670 feet

9. WATER LEVEL
 Static water level 470 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/28 20 04
 Date completed 6/6 20 04

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W D C Exploration Contractor
 Address P.O. Box 141 Zamora CA 95278 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources 2111
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6-16-04