WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.

OFFICE USE ONLY
Log No. 94787
Permit No.
Basin 184

51386 no cap & sat
NOTICE OF INTENT NO. RC 8-12-04

1. OWNER Beverly Bender
MAILING ADDRESS HCR 33 P.O. Box 33965
Ely, Nevada 89301

ADDRESS AT WELL LOCATION North Spring Valley Ranch

2. LOCATION NW ¼ SW ¼ Sec. 30 T. 17 N/S R. 67 E. White Pine County
PERMIT NO. (Issued by Water Resources) APN 010-380-16 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Hand Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This well was hand augered by previous owners (time frame unknown), sometime afterwards house was added on covering well. Well is now located next to kitchen stove at floor level.				
Well was abandoned by packing 5 gal. buckets of Neat Cement into house & pouring down well.				
Approximately 30 gals. of Grout was needed to plug well.				

RECEIVED 04 JUL 19 PM 2:47 STATE ENGINEERS OFFICE

Date started June 27, 2004
Date completed June 27, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased Unknown Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Unknown Inches	Feet	Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8"			Unknown	

Perforations:
Type perforation Unknown
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No Unknown
From feet to feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Oil Contaminated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rick Lewis By Gerald D. Christiansen
By driller performing actual drilling on site or contractor

Date July 13, 2004

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627