

OFFICE USE ONLY  
 Log No. 94795  
 Permit No. \_\_\_\_\_  
 Basin. 163

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26445

1. OWNER T THOMAS + DARLENE SNELSON ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2124 STONE CROFT ST. PAUTE ST. + GYPSUM AV.  
LAS VEGAS, NV. 89134 SANDY VALLEY NV.  
 2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 24 T. 24 N. R. 56 E. CLARK County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 200-24-401-009 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/LOAM + GRAVEL		0	4	4
CLAY + GRAVEL		4	97	93
GRAVEL	W.B	97	112	15
CLAY + GRAVEL		112	124	12
ROCK + GRAVEL	W.B	124	140	16

DCNR/DWRH  
RECEIVED  
JAN 12 2005  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 50 Feet  
10 5/8 Inches  
 From 50 Feet To 140 Feet  
9 7/8 Inches  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/2" INCH BY 6" INCH  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50 FT.  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

9. WATER LEVEL  
 Static water level 93 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started 12-1  
 Date completed 12-6

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET Drilling Co Contractor  
 Address P.O. Box 3505 Pahrump NV. Contractor  
89041  
 Nevada contractor's license number 40020 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Annice Brown  
 By driller performing actual drilling on site or contractor  
 Date 12-9-2004