

OFFICE USE ONLY
Log No. 94802
Permit No. _____
Basin. #230

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26276

1. OWNER Rick Webb ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 571 Kavanaugh Pl. Las Vegas, Nev. 89123 Happeney St. Amargass Valley, Nev. 89020
2. LOCATION SE 1/4 SE 1/4 Sec. 35 T. 16 N. R. 48 E. NYE County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Snd & gravel		0	50	50
limestone		50	65	15
VOID		65	75	10
limestone w/snd	<u>1st</u>	75	220	145
* clay layers - small voids thru out				
Bottom of well			220	

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 220 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>220</u>
<u>Surface Protective Casing:</u>				
<u>8</u>	<u>steel</u>	<u>.188</u>		<u>7</u>

Perforations:
Type perforation Machined
Size perforation 6 R. 0.32 screen
From 120 feet to 160 feet
From 180 feet to 200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 220 feet

DNH/DWR
RECEIVED
JAN 14 2005
LAS VEGAS OFFICE

9. WATER LEVEL
Static water level 77 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 12/20, 2004
Date completed 12/22, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HC 20 Box 543 Contractor
Amargass Valley, Nev. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed Rod [Signature]
By driller performing actual drilling on site or contractor
Date 11/8/05