

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26279

1. OWNER Jim Thomas ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 4517 Tennessee Walker Ave. Frontier & Mojave
No. Las. Vegas, NV. 89020 Amargosa Valley, NV. 89020
2. LOCATION SW 1/4 SW 1/4 Sec. 4 T. 16 N. R. 48 E. Nye County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel w/snd		0	125	125
gravel	1st	125	150	25
snd		150	165	15
tan cly.		165	175	10
limestone		175	180	5
gravel w/snd	2nd	180	195	15
sandy cly. w/ limestone layers		195	220	25
Bottom of well			220	

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 220 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		PVC	0	220
8		steel	0	7

Perforations:
Type perforation Machined
Size perforation 6R, .032 screen
From 140 feet to 160 feet
From 150 feet to 200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address H.C. 70 Box 543 Contractor
Amargosa Valley, NV. 89020
Nevada contractor's license number 5376-A issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2160
Signed Ray Thomas
By driller performing actual drilling on site or contractor
Date 12/30/04

DCNH/DWR
RECEIVED

JAN 07 2005

LAS VEGAS OFFICE

Date started 12/14 2004
Date completed 12/16 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)