

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 94830
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53372

1. OWNER Kevin Simkins ADDRESS AT WELL LOCATION 1430 5th St
 MAILING ADDRESS _____ SILVER SPRINGS, NV
 2. LOCATION SW 1/4 NE 1/4 Sec 7 T 17 N/S R 25 E LYON County
 PERMIT NO. _____
 Issued by Water Resources 17-144-05 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	8	8
BROWN CLAY		8	26	18
BR CLAY-GRAVEL		26	61	35
SANDY GRAVEL		61	88	27
BLACK SANDY CLAY		88	104	16
MEDIUM-LARGE GRAVEL		104	145	40

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>SDR 21</u>	<u>5</u>	<u>145</u>
			<u>+1</u>	<u>5</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation 0.40" x 4"
 From _____ feet to _____ feet
 From 135 feet to 145 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 145 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address PO BOX 1255 Carson City NV 89702

Date started 26 APR 2004
 Date completed 26 APR 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>1.0</u>

Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date _____

RECEIVED
 04 JUN 10 PM 3:39
 STATE ENGINEERS OFFICE