WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94833
Permit No.
Basin 64

NOTICE OF INTENT NO. 53857

1. OWNER Newmont mining Corp
MAILING ADDRESS P.O. Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION Twin Creeks mine, Golconda, NV
VD-107

2. LOCATION NE ¼ NW ¼ Sec. 30 T 39 N/S R 43 E Humbolt County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Vertical Drain # 109				
Pump Abandonment Fluid at 500' trough trimmy pump 150%. Fill hole up to 20' with 3/8 hole plug pour neat Cement Seal top 20'				
Materials used for Abandonment				
14-50lb SKS Super plug (800 gal)				
26-50lb SKS Kwik plug 3/8				
2-94lb SKS Cement				

Date started 10/09, 2004
Date complated 10/09, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½		¼ SL 80	0	600

Perforations:
Type perforation Slot
Size perforation .080
From 0 feet to 600 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 232 feet below land surface
Artesian flow NO G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drilling (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV, 89803

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-2089

Signed [signature] (By driller performing actual drilling on site or contractor)

Date 10/09/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627