

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25136

1. OWNER Dale Burbank ADDRESS AT WELL LOCATION Corner of Urdale Way and SR 168 Wagon Springs
MAILING ADDRESS PO Box 628 Moapa NV 89025 4720 W State Hwy 168

2. LOCATION S/4 N/4 Sec. 9 T. 14 N. R. 65 E. Clark County _____
PERMIT NO. 030-09-201-006-00g Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|----|------------|
| Sandy Clay | | 0 | 55 | 55 |
| gravel-boulders | Y | 55 | 75 | 20 |
| Clay-boulders | | 75 | 76 | 1 |

This was a well with no log bit with the stake. I planned on plugging it because it was only 34' TD when I went in to blow it to clean to TD before plugging. I discovered sand-boulders in well when it finally hit hard bottom at 76' well was producing enough water for domestic use. I believe well was drilled according to specs. I drilled a well nearby in 1998 so the lithologic log should be the same approx.

Date started 11-18-04, 19_____
Date completed 11-19-04, 19_____
7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. 27 Draw Down (Feet Below Static) _____ Time (Hours) _____
DONT FORGOT RECEIVED NOV 22 2004 LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 76 Feet Depth Cased 76 Feet
HOLE DIAMETER (BIT SIZE) unknown
From _____ To _____
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>8 5/8</u> | | <u>.188</u> | <u>0</u> | <u>76</u> |

Perforations:
Type perforation torch cut
Size perforation 1 3/4" x 12"
From 60 feet to 76 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50'
Placement Method: Pumped Poured

Gravel Packed: Yes No
From unknown feet to _____ feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps Contractor
Address HC 61 Box 54 Hiko NV 89017 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1121
Signed Mike Davis
By driller performing actual drilling on site or contractor
Date 11-19-04