

OFFICE USE ONLY  
 Log No. 94841  
 Permit No. \_\_\_\_\_  
 Basin. 2.12

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27157

1. OWNER Kids Rescue LLC Chris Navarro ADDRESS AT WELL LOCATION Pebble + Tenaya  
 MAILING ADDRESS Las Vegas, NV 8895 S Tenaya Wy Clark  
 2. LOCATION S 1/4 SW 1/4 Sec 15 T 22 N/S R 60 E County  
 PERMIT NO. 176-15461-033 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay-Gravel Boulders		0	250	250
Red Claystone		250	400	150
Cemented Gravel		400	450	50
Red Claystone		450	500	50
Limestone	✓	500	550	50
Clay w Gravel	✓	550	650	100

DUNN/DWR  
RECEIVED  
JAN 11 2005  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 650 Feet Depth Cased 650 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 650 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 Inch	F480	PVC	+1	650
5 FT	8 5/8 X 188		+1	4

Perforations:  
 Type perforation Saw  
 Size perforation 18x12  
 From 590 feet to 650 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50+  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-4, 2005  
 Date completed 1-7, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>2 HR.</u>

9. WATER LEVEL  
 Static water level 485 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Redding Drilling Contractor  
 Address 3955 Blue Diamond Rd #4 Contractor  
Las Vegas NV 89139  
 Nevada contractor's license number issued by the State Contractor's Board 38155  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617  
 Signed Floyd Mitchell  
 By driller performing actual drilling on site or contractor  
 Date 1-11-05