WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94842
Permit No.
Basin 212

NOTICE OF INTENT NO. 27153

1. OWNER Rose Street Realty
MAILING ADDRESS P.O Box 97631
LV NV 89193

ADDRESS AT WELL LOCATION
Tenaya + Gary
9564 S Tenaya Wy - D8B
Clark County

2. LOCATION SW ¼ SE ¼ Sec. 22 T 22 N/S R 60 E
PERMIT NO. Issued by Water Resources | 176-22-801-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay + gravel		0	3	3
Clay + gravel		3	30	27
Cemented gravel		30	50	20
Clay + Gravel		50	275	225
Soft White Rock		275	300	25
Clay gravel Blds		300	500	200
Limestone	X	500	530	30
Clay		530	540	10
Limestone	X	540	625	85
Red Claystone		625	655	30

DCNR/DWR
RECEIVED
JAN 11 2005
LAS VEGAS OFFICE

Date started 12-21, 2004
Date complated 12-31, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	TOTAL	3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 655 Feet Depth Cased 655 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	655 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	F480	PVC	+1	655

Perforations:
Type perforation SAW
Size perforation 1/8 x 8
From 575 feet to 635 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 473 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling
Contractor
Address 3955 Blue Diamond Rd #4
Contractor
LV NV 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Floyd Mitchell
By driller performing actual drilling on site or contractor
Date 1-3-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627