94868

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94868
Permit No.
Basin 212

NOTICE OF INTENT NO. 27040

1. OWNER Susan Madsen
MAILING ADDRESS
ADDRESS AT WELL LOCATION Rd To Mt Charleston
10380 Alexito St. DSB

2. LOCATION SE ¼ NW ¼ Sec. 6 T. 19S N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) 126-06-201-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[xx] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[xx] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[xx] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	395	
Red Clay & Gravel		395	510	
Red Shale & Water	xx	510	525	
Red Shale		525	560	
Red Shale & Water	xx	560	615	

UCNR/DWR
RECEIVED
JAN 27 2005
LAS VEGAS OFFICE

Date started 01/05/05, 20
Date completed 01/21/05, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 615 Feet Depth Cased 615 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	310 Feet
8 3/4 Inches		310 Feet	615 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	5
8	PVC	.500	-5	50
6 1/2	SRD PVC		-4	615

Perforations:
Type perforation Factory
Size perforation .032 Sieve type
From 560 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [xx] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [xx] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [xx] Concrete Grout
Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed (By driller performing actual drilling on site or contractor)
Date 01-24-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627