WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.360

OFFICE USE ONLY
Log No. 94904
Permit No.
Basin 212

NOTICE OF INTENT NO. 26175

1. OWNER Lawrense Canarelli
MAILING ADDRESS 250 Pilot Rd
Las Vegas, NV

ADDRESS AT WELL LOCATION 4520 W. Camero Ave
Enterprise, NV

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 22 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 177-18-201-007 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perforated Casing With Mills Knife with perforation Size of 2" long x 3/8" wide 4 times per Foot from a depth of 400' To a depth of 200' BGL Pressure grouted Casing with Tremic Hose from Bo Hom of Casing using Neat Cement				

DCNR/DWR
RECEIVED
JAN 04 2005
LAS VEGAS OFFICE

Date started 10-14, 2004
Date completed 10-19, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		Steel		

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Eagle Drilling Services LLC
Address (Contractor) 2150 Placid Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed (By driller performing actual drilling on site or contractor)
Date 11/11/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627