WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94913
Permit No.
Basin 212

NOTICE OF INTENT NO. 27621

1. OWNER DENNIS W. WHITING
MAILING ADDRESS 6418 E. VEGAS VALLEY
LAS VEGAS, NV 89112
ADDRESS AT WELL LOCATION 6418 E. VEGAS VALLEY DR
LAS VEGAS, NV 89142

2. LOCATION SE ¼ NE ¼ Sec. 10 T. 21 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 161-10-602-002 (Parcel No.) Subdivision Name DSB

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	14	
INTERBEDDED SAND & SANDY SILT		14	20	
SILTY SAND		20	24	
SANDY SILT		24	29	
CLAYEY SILT		29	33	
SILTY CLAY		33	38	
INTERBEDDED SAND & SANDY SILT & SILTY CLAY		38	44	
CLAYEY SILT		44	59	
SANDY SILT		59	60	

DCNR/DWR
RECEIVED
JAN 18 2005
LAS VEGAS OFFICE

Date started 12-14 2004
Date completed 12-15 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	60

Perforations:
Type perforation SLOT
Size perforation .020
From 35 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 31
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 33 feet to 60 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) TENN WELL AND ENVIRO SERVICE
Address (Contractor) 1973 NVELLIS #303
LAS Vegas NV 89115
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1953
Signed (By driller performing actual drilling on site or contractor)
Date 1-5-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627