WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94921
Permit No.
Basin 105

NOTICE OF INTENT NO. ~~63996~~ 53974

1. OWNER Michael & Katie Dillon
MAILING ADDRESS 1670 Coyote Rd.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1670 Coyote Rd.
Gardnerville

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T 13N N/S R 20E E Douglas County
PERMIT NO. _____ Issued by Water Resources
1320-26-002-011 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 8" x 136' well by perforating with mills knife at 4 around and at one foot intervals. We perforated from 130' to surface. There was no sanitary seal. We then pumped approximately 3.5 cu. yards of neat cement mixed 5.2 gallons of water per sack. We pumped, using tremie pipe, from the bottom to the top of the well. We then cut off the top 2' of the well.				

RECEIVED NOV 15 2004 DIV. OF WATER RESOURCES

Date started 11/12/2004, 19__
Date completed 11/12/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 136 Feet Depth Cased 136 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	136

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 0 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 109 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay By driller performing actual drilling on-site or contractor
Date 11/15/2004

USE ADDITIONAL SHEETS IF NECESSARY