WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94933
Permit No.
Basin 088

NOTICE OF INTENT NO. 53692

1. OWNER Leslie Hopkins
MAILING ADDRESS 15450 Callahan Ranch Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 15450 Callahan Ranch Rd.

2. LOCATION SW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 045-573-11 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray sand mixed boulders		140	320	180
Brown sand	x	320	340	20
Gray and black sand mixed boulders	x	340	360	20
Volcanic rock rainbow colors	x	360	401	41
Washoe County Well Permit # WL 040300				

RECEIVED 04 NOV 18 PM 1:53 NEVADA DIVISION OF WATER RESOURCES

Date started 11/6/2004, 19__
Date completed 11/10/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	50+		3
Pump	20	8	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 401 Feet Depth Cased 401 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	140 Feet	401 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	121	401

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 341 feet to 401 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/10/2004

USE ADDITIONAL SHEETS IF NECESSARY