

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51394

1. OWNER Don Ward ADDRESS AT WELL LOCATION Fairview Lane  
 MAILING ADDRESS 840 Avenue B approximately 1 Mile East of Ely  
Ely, Nevada 89301

2. LOCATION NE  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 11 T. 16 N. R. 63 E. White Pine County  
 PERMIT NO. \_\_\_\_\_ APN 010-460-06 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Boulders		3	18	15
Large Gravel	X	18	19	1
Brown Clay		19	22	3
Boulders & Brown Clay		22	27	5
Brown Clay & Small Gravel		27	55	28
Brown Clay		55	75	20
Water Sand & Gravel	X	75	78	3
Brown Clay		78	118	40
Brown Clay with Water	X	118		
Bearing Sand & Gravel				
Stringers			124	6
Brown Clay		124	127	3

8. WELL CONSTRUCTION  
 Depth Drilled 127 Feet Depth Cased 127 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 127 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	127

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" X 2 1/2" 6 Rows  
 From 63 feet to 127 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 127 feet

9. WATER LEVEL  
 Static water level 14 1/2 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301  
 Nevada contractor's license number 14790  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1793  
 Division of Water Resources, the on-site driller  
 Signed Rich Lurie By Jerald D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date October 25, 2004

Date started September 28 2004  
 Date completed October 6 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>55</u>	<u>106</u>	<u>1</u>

RECEIVED  
 04 NOV -3 AM 11:17  
 STATE ENGINEERS OFFICE