

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51395

1. OWNER Ely Shoshone Tribe ADDRESS AT WELL LOCATION 1 Mile S.E. of Ely
 MAILING ADDRESS #16 Shoshone Circle
Ely, Nevada 89301
 2. LOCATION SW 1/4 SE 1/4 Sec. 21 T. 16 N. 63 E. White Pine County
 PERMIT NO. 4-B Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Course Cemented Gravels		2	25	23
Cemented Sand & Gravel		25	110	85
Sand & Gravel with Clay Stringers		110	140	30
Cemented Sand & Gravel		140	230	90
Brown Clay		230	310	80
Sand & Small Gravel	X	310	315	5
Brown Clay		315	355	40
Sand & Small Gravel	X	355	360	5
Brown Clay		360	440	80
Brown Clay with Water Bearing Stringers	X	440	450	10
Brown Clay		450	461	11

8. WELL CONSTRUCTION
 Depth Drilled 461 Feet Depth Cased 461 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 461 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	461

Perforations:
 Type perforation Factory
 Size perforation 1/8" X 2 1/2" 6 Rows
 From 361 feet to 461 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 461 feet

9. WATER LEVEL
 Static water level 306 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis By Jerrold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date November 1, 2004

Date started October 8 2004
 Date completed October 14 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Foot Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	30	144	2

RECEIVED
 OCT 17 3 11 PM '04
 CIVIL ENGINEERS OFFICE