REPORT NO. A04.094

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 94942
PERMIT NO.
BASIN 105

NOTICE OF INTENT NO. 53268

1. OWNER Veronica Madeiros
MAILING ADDRESS P.O. Box 3226 Carson City, NV 89701

ADDRESS OF WELL 7492 Mackinly Ct.
Carson City, NV 89701

2. WELL LOCATION SW 1/4 SE 1/4 SEC. 5 T 14 R 20 E Carson City COUNTY

PERMIT NO PARCEL NO 9-822-08 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| Sand & Dirt | | 0 | 6 | 6 |
| Yellow, Red Clay & Sand | | 6 | 18 | 12 |
| Coarse Gravels | | 18 | 20 | 2 |
| Clay | | 20 | 22 | 2 |
| Sand & DG | | 22 | 35 | 13 |
| Gray Clay, Sand & DG | | 35 | 38 | 3 |
| Gravels & Red Clay | | 38 | 45 | 7 |
| Gray Clay, Sand, DG | | 45 | 70 | 25 |
| Gray & Red Clays And Gravels | | 70 | 75 | 5 |
| Gray Clay & Sand | | 75 | 80 | 5 |
| Green Clays, Sands, DG | | 80 | 125 | 45 |
| Gray, Green Clays Volcanic Rock | | 125 | | |
| & DG | | 125 | 200 | 75 |

RECEIVED
04 NOV -4 AM 11:15
STATE ENGINEERS OFFICE

Notes :

Date Started 10-25-04 Date Completed 10-27-04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | 20+ | | 2 1/2 HRS. |
| | | | |
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Depth Cased 200

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 200 |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation FAC SAW Size Perforation 3/32 X 3
From 180 Feet to 200 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [X] Pumped [ ] Poured
SEAL TYPE: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 200 Feet

9. WATER LEVEL
Static Water Level 15 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed
By driller performing actual drilling on site or contractor
Dated October 27, 2004