

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 94944  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53710

1. OWNER Thomas A. & Daphanie Hanson ADDRESS AT WELL LOCATION 581 Black Bear Trail  
 MAILING ADDRESS P.O. Box 8170 Gardnerville, Nevada 89460  
Gardnerville, NV 89460

2. LOCATION NW 1/4 NE 1/4 Sec. 26 T 12N N/S R 19E E Douglas County

PERMIT NO. 1219/26/001/037 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G.		0	112	112
Rock		112	119	7
D.G.		119	270	151
Rock		270	285	15
D.G.	x	285	400	115
T.D.		400		

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>12-5/8</u>	<u>0</u>		<u>400</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8-5/8</u>	<u>16.9</u>	<u>.188</u>	<u>+1-1/2</u>	<u>400</u>

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 1/8 x 3

From	Feet to	Feet
	<u>160</u>	<u>180</u>
	<u>200</u>	<u>220</u>
	<u>240</u>	<u>260</u>
	<u>280</u>	<u>300</u>
	<u>320</u>	<u>340</u>

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 100 feet to 400 feet

9. WATER LEVEL  
 Static water level +1-1/2 feet below land surface  
 Artesian flow 20 G.P.M. 2 P.S.I.  
 Water temperature cool °F Quality good

Date started 11/5/2004 19  
 Date completed 11/19/2004 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>	<u>400</u>	<u>5hrs</u>
	<u>30+</u>	<u>300</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Contractor  
 Address P.O. Box 60130 Contractor  
Reno, Nevada - 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-B  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 12/1/04

RECEIVED  
 04 DEC -6 AM 11:25  
 STATE ENGINEERS OFFICE