

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO S3C112

1. OWNER Derek Rosse ADDRESS AT WELL LOCATION 915 COUNTRY - MACKINLEY CREEK DR
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SE 1/4 Sec 5 T 14 N/S R 20 E CONSON County _____
 PERMIT NO. 09-823-10 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DIRT - BROWN CLAY</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>BROWN SAND & GRAVEL</u>	<input checked="" type="checkbox"/>	<u>6</u>	<u>46</u>	<u>40</u>
<u>BROWN CLAY</u>		<u>46</u>	<u>58</u>	<u>12</u>
<u>MEDIUM GRAVEL</u>	<input checked="" type="checkbox"/>	<u>58</u>	<u>106</u>	<u>48</u>
<u>BLACK SANDY CLAY</u>		<u>106</u>	<u>146</u>	<u>40</u>
<u>BLACK LARGE GRAVEL</u>	<input checked="" type="checkbox"/>	<u>146</u>	<u>195</u>	<u>49</u>

RECEIVED
 04 DEC -6 PM 3:24
 STATE ENGINEERS OFFICE

Date started 23 NOV 04
 Date completed 24 NOV 04

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>		<u>1.0</u>

8. WELL CONSTRUCTION
 Depth Drilled 195 Feet Depth Cased 195 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 195 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.88</u>	<u>1</u>	<u>15</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>15</u>	<u>195</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 155 feet to 195 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 101 FT Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 101 feet to 195 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING
 Address PO. BOX 1224 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date _____