

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 94928
Permit No.
Basin 092B

NOTICE OF INTENT NO 53623
9494 Spearhead Way

1. OWNER **Charles Lowther**
MAILING ADDRESS **9494 Spearhead Way**
Reno NV 89506

ADDRESS AT WELL LOCATION

2. Location **NW 1/4 NE 1/4 Sec 11 T 20N R 19E**
PERMIT NO. **PARCEL NO. 552-040-01**

SUBDIVISION NAME

Washoe County

3. WORK PERFORMED

New Well Replace Recondition
Deepen Abandon Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG.		0	83	83
Granite.		83	285	202

8. WELL CONSTRUCTION

Depth Drilled **285 feet** Depth Cased **285 feet**
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 inches **0** feet **50** feet
8 3/4 inches **50** feet **285** feet
inches feet feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FT (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	285

Perforations:

Type Perforation	Factory
Size perforation	3/32 x 3"
From	245 feet to 285 feet
From	feet to feet
From	feet to feet
From	feet to feet
From	feet to feet

Surface Seal YES No Seal Type:
Depth of Seal **50** feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From **50** feet to **285** feet

9. WATER LEVEL

Static water level **215** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

Date started **9-7 -04**
Date completed **9-14 -04**

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		x Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
	20	25			
	30	70			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**

Signed *[Signature]*
By driller performing actual drilling on site or contractor
Date **9-17 -04**

RECEIVED

04 NOV 22 PM 12:12

STATE ENGINEERS OFFICE

