WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 94998
Log No.
Permit No.
Basin 048

NOTICE OF INTENT NO. 49071

1. OWNER CAROLYN PECK / TRINITY WILSON
MAILING ADDRESS BOX 5951
EIKO, NV 89802

ADDRESS AT WELL LOCATION

2. LOCATION NW 1/4 NW 1/4 Sec. 30 T 33 N/S R 57 E EIKO County
PERMIT NO. 41509 Issued by Water Resources
006-52C-002 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	5	5
CLAY		5	65	60
SANDSTONE	X	65	85	20
BLUE CLAY		85	170	85
SANDSTONE	X	170	190	20
BLUE CLAY		190	235	45
SANDY CLAY	X	235	250	15
BLUE CLAY		250	265	15
SAND	X	265	295	30
BROWN CLAY		295	370	75
SAND	X	370	400	30
BROWN CLAY		400	610	210
SAND	X	610	625	15
BROW CLAY		625	645	20

RECEIVED
OCT 22 2004
STATE ENGINEER'S OFFICE

Date started 8-2-04, 19__
Date completed 9-17-04, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	800		OFF + ON 5 DAYS

8. WELL CONSTRUCTION
Depth Drilled 645 Feet Depth Cased 634 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
22	Inches	0	Feet	645	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	28.04	250	+2	120
10	41	375	120	634

Perforations:
Type perforation MILL SLOT
Size perforation 1/8 X 3"
From 120 feet to 634 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 634 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG dba FERTIG DRILLING Contractor
Address P.O. BOX 525 Contractor
EIKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Sharel C Fertig By driller performing actual drilling on site or contractor
Date 9-20-04

USE ADDITIONAL SHEETS IF NECESSARY