WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94999
Permit No.
Basin 106

NORTHERN Nevada Well Place

NOTICE OF INTENT NO. 52750

1. OWNER Jeff Brashode Building
MAILING ADDRESS
ADDRESS AT WELL LOCATION [redacted], Holebrook Jct (395)

2. LOCATION NW ¼ SE ¼ Sec. 18 T. 10 N/S R. 22 E. Douglas Co County
PERMIT NO. 70877 Issued by Water Resources
[redacted] 1022 78 002 062 changed July 1/04 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Note: 60' Surface set 10 5/8 x 250 + grouted for risk of artesian		1	60'	
Soil		1	4	
Soil Cobbles		4	16	
D.G. Clay		16	23	
DG Sand		23	34	
Clay		34	56	
Cobbles, Sand		56	73	
Clay		73	82	
Cobbles Sand		82	259	
Some Clay Streaks				

RECEIVED 04 SEP 17 AM 11:19 STATE ENGINEERS OFFICE

Date started 9/3/04, 20
Date complated 9/7/04, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 259 Feet Depth Cased 259 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	1 Feet	60 Feet
9 7/8 Inches	60 Feet	259 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8	25	250.	1	60
6 5/8	13.6	188.	1	259
PVC	3.60	SHC40	20	259

Perforations:
Type perforation Machine
Size perforation 3/16 x 4 x 4 rows
From 179 feet to 259 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15' feet to 259' feet

9. WATER LEVEL
Static water level 1+ feet below land surface
Artesian flow Yes 1 gpm G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc
Contractor
Address PO 599
Contractor
S.S. NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 9/9/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627