COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95006
Permit No.
Basin 107

NOTICE OF INTENT NO. 49471

1. OWNER WILLIAM & JOANNE MCMILLAN
MAILING ADDRESS PO BOX 360
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION 25 DESERT CREEK RD.
WELLINGTON, NEVADA 89444

2. LOCATION SE ¼ SW ¼ Sec 32 T 10 N R 24 E LYON County

PERMIT NO. (Issued by Water Resources) | 010-761-57 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDER & BROWN				
CLAY		0	260	
COBBLES & BROWN				
CLAY WITH SOME				
SMALLER GRAVELS		260	460	
BROWN CLAY		460	475	
COBBLES & GRAVEL				
WITH BROWN CLAY		475	570	

RECEIVED 03 OCT -4 PM 12: 12 STATE ENGINEERS OFFICE

Date started 09/15, 20 03
Date completed 09/26, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT	10-15	TOTAL DEPTH	8 HOURS

8. WELL CONSTRUCTION

Depth Drilled 570 Feet Depth Cased 570 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	460	Feet
6 5/8	Inches	460	Feet	570	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0+2	360
6 5/8		.188	380-400	420-440
5 3/16		.188	450	510

Perforations:
Type perforation MILL SLOT
Size perforation 3/32"
From 440 feet to 460 feet
From 400 feet to 440 feet
From 360 feet to 380 feet
From 510 feet to 570 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 460 feet

9. WATER LEVEL

Static water level 330 feet below land surface
Artesian flow NO G.P.M P.S.I
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (CONTRACTOR)
Address PO BOX 2227 (CONTRACTOR)
DAYTON, NEVADA 89403
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790

Signed Marty [illegible]
By driller performing actual drilling on site or contractor
Date 10/25/03

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com