

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 95007  
 Permit No. \_\_\_\_\_  
 Basin 108

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52910

1. OWNER Roy Scknow ADDRESS AT WELL LOCATION Roy Scknow  
 MAILING ADDRESS #70 Mason Pass Road #70 Mason Pass Road  
Yerington, NV 89447 Yerington, NV 89447

2. LOCATION sw 1/4 nw 1/4 Sec 32 T 14 N R 25 E Lyon County  
 PERMIT NO. 14-281-02

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	4	4
Brown Clay		4	8	4
Brown Clay		8	10	2
Sand/Gravel		10	15	5
Large Gravel		15	17	2
Sand/Gravel		17	21	4
Brown Clay		21	25	4
Brown Clay		25	31	6
Gray Clay		31	33	2
Brown Gray Clay		33	40	7
Sand Gravel		40	65	25
Gravel		65	70	5
Gray Clay		70	76	6
Brown Sand w/Clay		76	85	9
Gray Sand w/Clay		85	88	3
Gray Clay		88	92	4
Sand/Gravel		92	96	4
Brown Clay		96	101	5
Clay w/Gravel		101	120	19
Clay W/Sand		120	128	8
Brown Clay		128	137	9
Brown Gray Sand		137	153	16
Brown Gravel/Clay		153	160	7
Brown Gravel		160	204	44
Gravel w/Clay		204	212	8
Brown Clay		212	230	18
Brown Gravel/Sand	XXX	230	236	6

8. WELL CONSTRUCTION  
 Depth Drilled 236 Feet Depth Cased 236 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches \_\_\_\_\_ Feet 236 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	236

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet 236 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling Inc  
 (CONTRACTOR)

Address P.O. Box 1265  
 (CONTRACTOR)  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons  
 By driller performing actual drilling on site or contractor  
 Date 10/01/04

Date started 07/21, 20 04  
 Date completed 07/21, 20 04

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		

RECEIVED  
 04 OCT - 6 PM 11:25  
 STATE ENGINEERS OFFICE