WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95013
Permit No.
Basin 107

NOTICE OF INTENT NO. 48944

1. OWNER Henry Kidder
MAILING ADDRESS No. 8 Terrell Ln Wellington Nev. 89444
ADDRESS AT WELL LOCATION No. 8 Terrell Ln TERRELL LANE Wellington Nev. 89444

2. LOCATION ~~NW~~ ~~SE~~ ¼ Sec. 33 T. 12 N/S R. 23 E. Lyon County
PERMIT NO. SW NE (Issued by Water Resources) | 09-034-07 (Parcel No.) | Dine Nut Ranch Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
alluvial DG + large rock		0	55	55
Brown clay + smaller rock		55	160	105
sharp gravel + coarse sand	yes	160	185	25
sand + gravel with small clay seams	Yes	185	215	30
hard bed rock		215	220	5

RECEIVED 04 NOV 16 AM 11:07 STATE OF NEVADA OFFICE

Date started Oct 22, 2004
Date complated Oct 29, 2004

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	5 ft	6 hrs

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	220 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	220

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 X 3
From 170 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From — feet to — feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O. Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Nov. 14 - 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627