WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95014
Permit No.
Basin 107

NOTICE OF INTENT NO. 54582

1. OWNER Sharon Hall
MAILING ADDRESS P.O. Box 2354 Minden Nev. 89423
ADDRESS AT WELL LOCATION 135 Sundance In Wellington Nev. 89444

2. LOCATION SW ¼ NE Sec. 12 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 10-401-24 | Subdivision Name Sundance

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam top soil	-	0	12	12
hard pan		12	15	3
sandy brown clay		15	55	40
dark fine sand	yes	55	65	10
fine + coarse dark sand	yes	65	130	65
blue gray clay		130	135	5

RECEIVED
05 JAN -4 AM 11:12
STATE ENGINEERS OFFICE

Date started Nov. 15, 2004
Date complated Nov. 19, 2004

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	5 ft	4 hrs

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
6 Inches	50 Feet	135 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	135

Perforations:
Type perforation 1/16 X 3 Factory saw
Size perforation 1/16 X 3
From 105 feet to 1350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92 Smith Contractor Nev. 89430
Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date Nov 20 - 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627