

Log No. 95040
Permit No. _____
Basin 106

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348

NOTICE OF INTENT NO. 53517

1. OWNER James KOZEN ADDRESS AT WELL LOCATION 1554 ALBAVISTA
MAILING ADDRESS 7343 Almaden Ln Gardnerville NV
Carlsbad, CA 92009
2. LOCATION SE 1/4 SW 1/4 Sec. 18 T. 10 N/S R. 23 E Douglas County County
PERMIT NO. 1022-18-002-017 lot 14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------------------|--------------|------|-----|------------|
| Loose Gravel Brown, red | | 0 | 18 | 18 |
| Boulder, Red Brown | | 18 | 22 | 4 |
| Clay + Gravel Red Brown + white | | 22 | 38 | 16 |
| Caving, Sand Brown | | 41 | 105 | 64 |
| Gravel Red Brown White Water | | 105 | 118 | 13 |
| Rock Soft + Brown White | | 118 | 160 | 42 |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet
HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 50 Feet
10 1/4 Inches 50 Feet 150 Feet
6 Inches 150 Feet 160 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Pt. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>13</u> | <u>0.188</u> | <u>+1'</u> | <u>160</u> |

Perforations:
Type perforation Factory
Size perforation 1/8 x 3"
From _____ feet to _____ feet
From 80 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 8.2 feet below land surface
Artesian flow N-A G.P.M. N-A P.S.I.
Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Santori Development Contractor
Address PO Box 7119 Contractor
Gardnerville NV 89460
Nevada contractor's license number B-2 - 0056886
issued by the State Contractor's Board 023 - 0057531
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 1652
Signed George E. Steele
By driller performing actual drilling on site or contractor
Date _____

Date started 3-23 2004
Date completed 5-10 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---------------|------------|-------------------------------|--------------|
| <u>Bailer</u> | <u>10+</u> | <u>8</u> | <u>3</u> |

RECEIVED
04 JUN 19 AM 10:49
STATE ENGINEERS OFFICE