WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95070
Permit No. 62691
Basin 215

NOTICE OF INTENT NO. ~~26335~~ 26696

1. OWNER Sandia Sand & Gravel
MAILING ADDRESS 1973 N. Nellis Blvd
Las Vegas, Nv 89115
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 20 N OR 64 E Clark County
PERMIT NO. 62691 (Issued by Water Resources) 142-00-002-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, sand, gravel				
Cobbles, - cemented		0	58	58
Sandstone - Brown		58	70	
Siltstone - orange, brown		70	110	
Sandstone - orange, gray		110	160	
Volcanics - gray		160	210	
Siltstone - orange, yellow		210	250	
Gypsum - gray, white		250	260	
Sandstone - yellow		260	270	
Volcanics - gray		270	390	
Siltstone - gray	X	390	480	
Siltstone - brown, gray	X	480	600	
Sandstone - brown, gray	X	600	690	
Siltstone - white, blue		690	730	
Siltstone - brown	X	730	800	
Mixed sandstone				
Limestone, siltston				
gray and brown	X	800	840	
Siltstone - brown				
orange, gray	X	840	940	

DCNR/DWR
RECEIVED
FEB 14 2005
LAS VEGAS OFFICE

Date started June 15, 2004
Date completed Sept. 30, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
500	73'	30 days

8. WELL CONSTRUCTION
Depth Drilled 940 Feet Depth Cased 940 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
30	0	80
20	80	940

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	52.73	.250	+2	80
12 3/4	41.38	.312	+2	940

Perforations:
Type perforation Factory milled
Size perforation 1/8 x 2 1/2
From 375 feet to 940 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 110
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 110 feet to 940 feet

9. WATER LEVEL
Static water level 301.4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling (Contractor)
Address 2475 W. 3935 S. (Contractor)
WVC, Ut. 84119
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone (By driller performing actual drilling on site or contractor)
Date Dec. 30, 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627