

OFFICE USE ONLY
 Log No. 95146
 Permit No. 1106
 Basin 1106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53435

1. OWNER Bob Birchfield ADDRESS AT WELL LOCATION 4075 Hwy 208
 MAILING ADDRESS 17986 Palm Drive
Hesperia Calif 92345
 2. LOCATION SE 1/4 NW 1/4 Sec 14 T 10 N/S R 22 E Douglas County
 PERMIT NO. 1022-14-001-023 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-GRAVEL		0	14	14
BROWN CLAY-GRAVEL		14	60	46
MEDIUM GRAVEL		60	72	12
BROWN CLAY-GRAVEL		72	140	68
MEDIUM GRAVEL		140	170	30

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>71</u>	<u>10</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>10</u>	<u>170</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .040" X 5"
 From _____ feet to _____ feet
 From 150 feet to 170 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 170 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. BOX 1255 Carson City NV 89702

Date started July 2, 2004
 Date completed July 2, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25T</u>		<u>1.0</u>

Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dalton
 By driller performing actual drilling on site or contractor
 Date _____

RECEIVED
 04 JUL 15 AM 9:01
 STATE ENGINEERS OFFICE