WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95175
Permit No.
Basin 227A

NOTICE OF INTENT NO. 24686

1. OWNER Nye County
MAILING ADDRESS 1210 E. Basin Rd Ste 6.
Pahrump Nv 89060

ADDRESS AT WELL LOCATION NC-EWDP-22RC

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 14 N/S R. 49 E/W County
PERMIT NO. R-1091 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium Gravel	No	0	471	471
Alluvium Gravel	Yes	471	763	292

DCNR/DWR
RECEIVED
MAR 01 2005
LAS VEGAS OFFICE

Date started 10/14/04, 19
Date completed 11/23/04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
None		

8. WELL CONSTRUCTION
Depth Drilled 763 Feet Depth Cased 760.5 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
16 3/4" / 11 7/8"	0 / 60.7	60.7 / 460
7 7/8" / 6.3"	460 / 589.6	589.6 / 625.3
5.8 / 4.7	625.3 / 759.4	759.4 / 763

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	5	0.365"	0	460
2.375	.958	.218	0	585.3
2.375	.958	.218	0	760.5

Perforations:
Type perforation Factory Slotted
Size perforation 0.020"
From 510.0 feet to 579.8 feet
From 665.4 feet to 755.0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 505.2
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout Bentonite Grout
Gravel Packed: ☒ Yes ☐ No
From 505-505.2 feet to 763-659.2 feet

9. WATER LEVEL
Static water level 471 feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature 82 °F Quality 760' depth good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Brent Longyear
Contractor
Address 7713 W Seldon Lane
Contractor
Peoria AZ 85345
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2147
Signed
By driller performing actual drilling on site or contractor
Date 1-17-05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627