

mw-1

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 95186  
Permit No. \_\_\_\_\_  
Basin Q12

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24692

1. OWNER CITY OF HENDERSON ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS PO Box 95050 Henderson NV 89009-5050 NW CORNER OF STEPHANIE & WING WORN PKWY HENDERSON, NV  
2. LOCATION NW 1/4 NE 1/4 Sec. 16 T. 22 N. 62 E. County \_\_\_\_\_  
PERMIT NO. 178-16-501-001 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Brown silty sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>COBBLES BROWN CLAY</u>		<u>10</u>	<u>25</u>	<u>15</u>
<u>MOIST</u>				
<u>GRAVEL, SAND COBBLES</u>		<u>25</u>	<u>30</u>	<u>5</u>
<u>BROWN CLAY, COBBLES</u>		<u>30</u>	<u>35</u>	<u>5</u>
<u>SAND, COBBLES</u>		<u>35</u>	<u>40</u>	<u>5</u>
<u>SAND, COBBLES</u>		<u>40</u>	<u>45</u>	<u>5</u>
<u>SILTY CLAY, GRAVEL</u>		<u>45</u>	<u>55</u>	<u>10</u>
<u>SILTY SAND COBBLES</u>		<u>55</u>	<u>60</u>	<u>5</u>
<u>TAN SILTY SAND GRAVEL</u>		<u>60</u>	<u>70</u>	<u>10</u>

8. WELL CONSTRUCTION  
Depth Drilled 70 Feet Depth Cased 70 Feet  
HOLE DIAMETER (BIT SIZE)  
6" Inches From 0 Feet To 70 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Sch 40</u>	<u>.308</u>	<u>0</u>	<u>10</u>

Perforations:  
Type perforation FACTORY CUT  
Size perforation 0.020  
From 10 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 6.5 feet  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 25 feet to 8 feet

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name ROBERT SALDIS (BOART LONGYEAR CO.) Contractor  
Address PO Box 1000 325 STOKES DR DAYTON NV 89403 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 00101587  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2270  
Signed [Signature] by driller performing actual drilling on site or contractor  
Date 12-27-04

Date started 12-27, 2004  
Date completed 12-27, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR  
RECEIVED  
MAR 01 2005  
LAS VEGAS OFFICE