

Stagecoach
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 95196
 Permit No. _____
 Basin 103
 NOTICE OF INTENT NO. 52000

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Glady's Cruise ADDRESS AT WELL LOCATION 5010 Hackamore Stagecoach, Nev.
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 34 T. 18 N/S R. 23 E Lyon county
 PERMIT NO. 19-121-02 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand Clay Boulders</u>		<u>0</u>	<u>50</u>	
<u>Clay & Sand</u>		<u>50</u>	<u>65</u>	
<u>Sulfidated gravel & clay</u>		<u>65</u>	<u>180</u>	
<u>Clay & gravel</u>		<u>180</u>	<u>280</u>	
<u>Sand gravel & white clay</u>		<u>280</u>	<u>320</u>	

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 280 Feet
5 1/2 Inches 280 Feet 320 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.88</u>	<u>0</u>	<u>280</u>
<u>5</u>		<u>1.88</u>	<u>280</u>	<u>320</u>

 Perforations:
 Type perforation 5/8" factory milled
 Size perforation 3/32"
 From _____ feet to _____ feet
 From 280 feet to 280 feet
 From _____ feet to _____ feet
 From 300 feet to 320 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 260 feet

RECEIVED
 04 JUN 23 AM 11:44
 STATE ENGINEERS OFFICE

Date started 5-26-04, 20____
 Date completed 5-29-04, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>7</u>	<u>300</u>	<u>2 Hrs</u>

9. WATER LEVEL
 Static water level 93 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling P.O. Box 599
 Address Silver Springs NV
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
 Signed [Signature]
 Date 5-28-04
 By driller performing actual drilling on site or contractor