WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95201
Permit No.
Basin 071

NOTICE OF INTENT NO. 41541

1. OWNER C Dan Meiske
MAILING ADDRESS 639 E. 2nd St #1
Winn NV 89445

ADDRESS AT WELL LOCATION ~~6095~~ 6095 Water Canyon

2. LOCATION ¼ NW ¼ Sec 3 T 35 N/S R 38 E Humboldt County
PERMIT NO. Issued by Water Resources | 10-671-08 Parcel No. | Chris + Sonya Mitchell Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	5	5
Boulders		5	70	65
Clay		70	75	5
Boulders		75	105	30
Clay		105	115	10
Boulders		115	150	35
Hard Rock		150	160	10
Clay		160	180	20
		~~180~~	~~330~~	
Boulders		180	330	150
Clay		330	340	10
Boulders		340	360	20
Boulders + Clay		360	375	15
Gravel	yes 40 GPM	375	395	20
Boulders		395	400	5

N 40°56.630
W 117°41.863
Elevation 4982

Date started March 28 2002
Date completed April 5 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		4

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 398 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	398

Perforations:
Type perforation Factory cut
Size perforation 7/32"
From 368 feet to 398 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 90
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 90 feet to 400 feet

9. WATER LEVEL
Static water level 184' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FREA ANDERSON DRILLING Contractor
Address 10760 GRASS VALLEY ROAD Contractor
WINNEMUCCA, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed ~~By driller performing actual drilling on site or contractor~~
Date April 25-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627