WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95207
Permit No.
Basin 045

NOTICE OF INTENT NO. 52203

1. OWNER LEONARD HOPKINS
MAILING ADDRESS HC 36, BOX 32
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 371 SUN MOUNTAIN LANE

2. LOCATION NW 1/4 NE 1/4 Sec. 26 T 33N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) 023-016-008 (Parcel No.) PLEASANT VALLEY (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other PUMPRIG

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| FOUND OLD DRILL LOG - THE HOLE WAS PERFORATED FROM 110' TO 150' - WE USED A KNIFE TO PERFORATE 4 SLOTS PER FOOT ON THE CASING FROM 110' TO 45' 6 BAGS OF ABANDONITE FROM 150' TO 30' 3 BAGS OF CEMENT FROM 30' TO SURFACE 1 1/4" PIPE WAS SET TO 150' AND THE ABANDONITE WAS PUMPED FROM THE BOTTOM OF THE HOLE - THE CEMENT WAS POURED FROM THE SURFACE | | | | |

RECEIVED 04 AUG 30 PM 12:30 STATE ENGINEER'S OFFICE

Date started 8/10/2004, 19__
Date completed 8/11/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .250 | -6 | 150 |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: Neat Cement, Cement Grout, Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wiest (By driller performing actual drilling on-site or contractor)
Date 8/11/2004

USE ADDITIONAL SHEETS IF NECESSARY