COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95208
Permit No.
Basin 101

NOTICE OF INTENT NO. 53800

1. OWNER Jess Reid
MAILING ADDRESS 880 Laxy Heart Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION Jess Reid
4585 Rancheria Drive
Fallon, NV 89406

2. LOCATION sw ¼ nw ¼ Sec 16 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-121-90 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Clay		15	35	20
Sand & Clay		35	40	5
Sand		40	44	4
Clay		44	60	16
CLay & Sand		60	62	2
Black Clay		62	64	2
Black Sand		64	80	16
Gray Clay		80	82	2
Gray Sand		82	90	8
Brown Sand		90	116	26
Green Clay		116	118	2
Gray Clay		118	120	2
Gray Sand		120	125	5
Black Clay		125	145	20
Black Sand		145	155	10
Gray Clay		155	157	2
Gray Sand		157	170	13
Gray Clay		170	185	15
Brown Clay		185	190	5
Brown Sand		190	205	15

RECEIVED 04 OCT -6 PM 1:26 STATE ENGINEERS OFFICE

Date started 09/22, 20 04
Date completed 09/23, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	205 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	205

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 200 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 205 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 10/01/04

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com