COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95213
Permit No.
Basin 101
NOTICE OF INTENT NO. 53797

1. OWNER **Bruce Homer**
MAILING ADDRESS **325 River Village Drive**
Fallon, NV 89406

ADDRESS AT WELL LOCATION **Bruce Homer**
2144 Gummow Drive
Fallon, NV 89406

2. LOCATION **SE** ¼ **ne** ¼ Sec **23** T **19** N R **28** E **Churchill** County

PERMIT NO. (Issued by Water Resources) **008-252-11** (Parcel No) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	15	10
Brown Sand		15	30	15
Gray Clay		30	40	10
Gray Sand		40	60	20
Gray Clay		60	75	15
Gray Sand		5	80	15
Brown Sand		80	84	4
Brown Clay		84	90	6
Brown Sand	XX	90	105	15

RECEIVED 04 OCT -6 PM 1:25 STATE ENGINEERS OFFICE

Date started 09/13, 20 04
Date completed 09/13, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	105 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	105

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 100 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 105 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Parsons Drilling Inc** (CONTRACTOR)
Address **P.O. Box 1265** (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board **29064**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1454**
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 10/01/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com