REPORT NO. A04.046

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 95224
PERMIT NO.
BASIN 83
NOTICE OF INTENT NO. 52128

2850

1. OWNER Rick & Cindy Wiley
MAILING ADDRESS P.O. Box 623 Virginia City , NV 89440
ADDRESS OF WELL 285 Bullfrog Rd.
Virginia City Highlands, NV 89521

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 28 T 18 R 21 E Storey COUNTY

PERMIT NO PARCEL NO 03-351-41 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Hard Blue & White Speced		0		
Volcanic Rock		0	15	15
Red & White Speced Vol. Rock		15	50	35
Dark Reddish Brown Vol. Rock		50	90	40
Dark Blue Green & Red		90		
Volcanic Rock		90	110	20
Drk. Red Green Specs, Brown Clay		110	120	10
Reddish Brown Volcanic Rock		120	150	30
Maroon & Dark Blue Volcanic Rock		150	290	140
Blue Green Volcanic Rock		290	340	50
Fractured Blue Rock, White Specs		340	360	20
Fractured Blue With Specs of		360		
Yellow Volcanic Rock		360	377	17

RECEIVED
04 JUN 23 AM 11:43
STATE ENGINEERS OFFICE

Notes : UTM:
0273706
4364182 Elevation: 5823'.

Date Started 5/28/04 Date Completed 6/3/04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20		2Hrs.

8. WELL CONSTRUCTION
Depth Drilled 377 Depth Cased 377

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 330 Feet
7 7/8 Inches 330 Feet 377 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2' 6"	377

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 X 3
From 337 Feet to 377 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 377 Feet

9. WATER LEVEL
Static Water Level 130 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed Roger Mitchell
By driller performing actual drilling on site or contractor
Dated June 3, 2004