

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 95243
 Permit No. _____
 Basin 16a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26878

1. OWNER Dan Summers ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3731 E. McGraw 3731 E. McGraw
Pahrump, NV 89040
 2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-273-51 Green Saddle Ranch
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	16	16
brown caleche		16	21	5
See next line		21	60	39
brown clay with caleche strings				
brown caleche	x	60	64	4
See next line	x	64	108	44
brown clay with caleche strings				
brown clay	x	108	158	50
brown caleche	x	158	163	5
brown clay	x	163	165	2

DCNR/DWR RECEIVED
MAR 10 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	165

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 125 feet to 165 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 165 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed _____
 By driller performing actual drilling on-site or contractor
 Date 3-7-05

Date started 2/10/05, 19____
 Date completed 2/10/05, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			