DW 7 Abandon

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR DWR USE ONLY
Log No. 35794
Permit No. 55503
Basin 137B

NOTICE OF INTENT NO. 25446

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS PO Box 480
Round Mountain Nv 89045
ADDRESS AT WELL LOCATION Minesite - in Pit

2. LOCATION NE 1/4 NW 1/4 Sec. 30 T. 10 N/S R. 44 E. Nye County
PERMIT NO. 55503 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cut out welded plate from between 12" and 8" Csg.				
Pour in 560 sks of 3/8" cut Enviro-Plug into well and between 8" Csg and bore hole, to 50' level				
Mix Neat Cement, Pour in well to Top.				

Date started 9-6, 1995
Date completed 9-6, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 1/2 Inches		0 Feet	60 Feet
10 3/4 Inches		60 Feet	600 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	+1	60
8	22.36	.250	+1	600

Perforations:
Type perforation Milled
Size perforation 1/8 x 3
From 340 feet to 540 feet
From 580 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ~~☒ Pumped~~ ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling (Contractor)
Address 2220 Stowe Dr (Contractor)
Reno Nv 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Woytek (By driller performing actual drilling on site or contractor)
Date 9-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627