COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95256
Permit No.
Basin 093

NOTICE OF INTENT NO. 49878

1. OWNER Frank and Nicole Linney
MAILING ADDRESS 2750 Argonaught Way
Reno, NV 89506

ADDRESS AT WELL LOCATION
~~2785~~ Argonaught Way 2750 Re 11-22-04
Reno, NV 89506

2. LOCATION SW ¼ SW ¼ Sec 25 T 22 N R 19 E Washoe County

PERMIT NO. N/A (Issued by Water Resources) | 079-460-02 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	68	68
Clay		68	75	7
Decomposed Granite		75	84	9
Granite		84	290	206
Granite with white quartz stringers	xx	290	333	43

RECEIVED 04 OCT 21 AM 11:05 STATE ENGINEERS OFFICE

Date started 8-18, 20 04
Date completed 8-23, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	25	320	3

8. WELL CONSTRUCTION

Depth Drilled 333 Feet Depth Cased 333 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	20 Feet
10 Inches	20 Feet	333 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8" steel	14	.188"	-1'	7
6 5/8" PVC		SDR 17	7	333

Perforations:
Type perforation Mill Slot
Size perforation .030
From 263 feet to 333 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60' ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 333 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow none G.P.M none P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING CO. (CONTRACTOR)
Address P.O. Box 8056 (CONTRACTOR)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 037915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418-T1
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 9-21-04