WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95270
Permit No.
Basin 163

NOTICE OF INTENT NO. 27600

1. OWNER KEVIN MILLER
MAILING ADDRESS
ADDRESS AT WELL LOCATION EARL AV. & ARTESA ST. SANDY VALLEY NV.

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 24 N/S R. 57 E. CLARK 230 E County
PERMIT NO. (Issued by Water Resources) 201-31-301-013 (Parcel No.) Subdivision Name EARL ST

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CLAY		6	38	32
CALICHIE		38	44	6
CLAY		44	54	10
CALICHIE		54	58	4
CLAY		58	65	7
CALICHIE	W.B	65	69	4
CLAY		69	88	19
CALICHIE	W.B	88	94	6
CLAY		94	112	18
CALICHIE	W.B	112	120	8
CLAY		120	132	12
CALICHIE	W.B	132	138	6
CLAY		138	140	2

DCNR/DWR
RECEIVED
MAR 07 2005
LAS VEGAS OFFICE

Date started 1-14 2005
Date completed 1-19 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation SAW CUT
Size perforation 1/8" INCH BY 6 INCH
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO (Contractor)
Address P.O. BOX 3505 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed (By driller performing actual drilling on site or contractor)
Date 2-9-2005

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627