COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95276
Permit No.
Basin 106

NOTICE OF INTENT NO. 53526

1. OWNER J&D CONSTRUCTION
MAILING ADDRESS 1292 INDUSTRIAL CT UNIT 2
GARDNERVILLE, N V89410

ADDRESS AT WELL LOCATION 1557 ALBA VISTA
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ NW ¼ Sec 18 T 10 N R 22 E DOUGLAS County

PERMIT NO. | Issued by Water Resources | 1022-18-002-028 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
VOLCANIC SAND AND		0	4	4
GRAVELS				
BROWN CLAY AND		4	9	5
SMALL GRAVELS				
SMALL GRAVELS AND		9	86	77
SANDS				
RUSTY CLAY		86	145	59
SMALL GRAVELS		145	168	23
BROWN CLAY		168	189	21
FRACTURED SOFT SANDS AND GRAVELS	XXX	189	240	51

RECEIVED 04 NOV -5 AM 11:20 STATE ENGINEER'S OFFICE

Date started 10/16, 20 04
Date completed 10/18, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	55	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
sdr21 6 5/8	4.06	.216	20	240

Perforations:
Type perforation SAW CUT
Size perforation 3X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M ~~20~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, N V89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/20/04

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429