


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 95286  
Permit No.  
Basin 085



NOTICE OF INTENT NO 52032  
711 Encanto

1. OWNER **Morros Construction**  
MAILING ADDRESS **711 Encanto  
Reno NV**

ADDRESS AT WELL LOCATION

2. Location **NE 1/4 NE 1/4 Sec 17 T 21N R 21E Washoe County**  
PERMIT NO. **PARCEL NO. 076-300-38** SUBDIVISION NAME

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other  Mud

6. LITHOLOGIC LOG				
Material	Water/Strata	From	To	Thickness
Clay brown.		0	5	5
Sand.		5	12	7
Sand & clay.		12	20	8
Hard gray granite.		20	115	95
Med hard granite.		115	250	135
Soft granite.		250	325	75
Granite with limestone.		325	332	7
Hard granite black.		332	345	13
Black granite.		345	395	50
Granite with clay		395	508	113
Med hard granite		508	517	9
White granite.		517	525	8
Black granite.		525	650	125
Soft gray granite.		650	730	80

8. WELL CONSTRUCTION				
Depth Drilled	730 feet	Depth Cased	730 feet	HOLE DIAMETER (BIT SIZE)
		From	To	
	11 inches	0 feet	60 feet	
	8 3/4 inches	60 feet	603 feet	
	6 1/8 inches	603 feet	730 feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	603
5 9/16	6.96	188	575	730
Perforations:				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
From	283 feet	to	303 feet	
From	583 feet	to	603 feet	
From	690 feet	to	730 feet	
From		to		
From		to		
Surface Seal X YES No Seal Type:				
Depth of Seal	84 feet	Neat Cement		
		Pumped X Cement Grout		
		x Poured Concrete Grout		
Gravel Packed: x Yes No				
From	84 feet	to	603 feet	
WATER LEVEL				
Static water level	450 feet	below land surface		
Artesian flow	0 GPM	0 P.S.I.		
Water Temperature	cold	Degrees F	Quality	

See Deepening Log # 110389

Date started 9-13 -04  
Date completed 10-1 -04

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	
5	250	1	

GPS: 39.694° N 119.646° W

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **1261T2**  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 10-5 -04