

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 95302  
 Permit No. 089  
 Basin 089  
 NOTICE OF INTENT NO. 52253

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lee & Christine Reedy ADDRESS AT WELL LOCATION 4045 Eastlake Blvd.  
 MAILING ADDRESS 4045 Eastlake Blvd.  
Washoe Valley, NV 89704

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 17N N/S R 20E E Washoe County  
 PERMIT NO. 050-416-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG coarse sand rock				
Granite		0	24	24
Rock granite		24	29	5
Brown DG		29	68	39
Granite brown	x	68	180	112
Salt & pepper granite fractures	x	180	255	75
Washoe County Well Permit # WL040303				

RECEIVED  
 04 NOV - 9 AM 10:47  
 STATE ENGINEERS OFFICE

Date started 10/25/2004, 19  
 Date completed 10/26/2004, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>		<u>3</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 5/8</u>	<u>0</u> Feet	<u>170</u> Feet
<u>6 1/8</u>	<u>170</u> Feet	<u>255</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>170</u>
<u>5</u>	<u>10.79</u>	<u>.188</u>	<u>155</u>	<u>255</u>

Perforations:  
 Type perforation Machine cut  
 Size perforation 3/32 x 3

From <u>130</u> feet to <u>170</u> feet
From <u>215</u> feet to <u>255</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 60

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 60 feet to 170 feet

9. WATER LEVEL  
 Static water level 113 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce Mackay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010

Signed R. Bruce Mackay  
 By driller performing actual drilling on-site or contractor  
 Date 10/27/2004