REPORT NO. A04.099

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 95306
PERMIT NO.
BASIN Ø83
NOTICE OF INTENT NO. 53295

1. OWNER Skiets Grenke
MAILING ADDRESS 405 Circle Dr. Reno, NV 89509
ADDRESS OF WELL 3600 Overland
Virginia City Highlands, NV 89521

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 33 T 18 R 21 E Storey COUNTY
PERMIT NO PARCEL NO 03-381-17 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Hard Drk. Green Virtical Fractured		0		
Rock & Specs of Yellow Clay		0	225	225
Red Vol. Rock, Reddish Brown		225		
Sandy Clay, Light Green Hard Rock	X	225	345	120
Multi Color Volcanic Rock &		345		
Reddish Brown Sandy Clay		345	410	65
Gray, Blue Hard & Soft Clay &		410		
Multi Color Volcanic Rock	X	410	520	110
Gray Blue Volcanic Rock Less Clay		520	630	110
Blue Green Reddish Vol. Rock		630		
& Brown Clay		630	650	20
Soft Pinkish Volcanic Rock		650	720	70
Firmer Dark Green Volcanic Rock		720	810	90
Specs of Reddish Vol. Rock, Gray		810		
Volcanic Rock No Clay	X	810	854	44

RECEIVED 04 NOV 22 PM 12:1 STATE ENGINEER'S OFF

Notes : UTM:
0274225
4361772 Elevation: 6210'

Date Started 11/4/04 Date Completed 11/16/04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	18		5 1/2Hrs

8. WELL CONSTRUCTION
Depth Drilled 854 Depth Cased 854

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 557 Feet
6 1/4 Inches 557 Feet 854 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	557
5	9.69	.188	534	854

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 X 3
From 517 Feet to 537 Feet
From 814 Feet to 854 Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 557 Feet

9. WATER LEVEL
Static Water Level 398 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed
By driller performing actual drilling on site or contractor
Dated November 16, 2004