

OFFICE USE ONLY  
 Log No. 95330  
 Permit No. \_\_\_\_\_  
 Basin LO

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53066

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER CASEY PROPERTIES/WILLHITE ADDRESS AT WELL LOCATION 7089 ANNETTE  
 MAILING ADDRESS 4240 RENO HWY  
FALLON, NV 89406  
 2. LOCATION SE 1/4 SW 1/4 Sec. 1 T 19 N/S R 27 E CHURCHILL County  
 PERMIT NO. 7-122-23 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	
BROWN SAND		1	20	19
BROWN CLAY		20	28	8
BROWN SAND		28	38	10
GRAY CLAY/SAND		38	60	22
GRAY SAND		60	100	40
GRAY CLAY		100	115	15
GRAY SAND		115	150	35
GRAY CLAY		150	155	5
GRAY SAND		155	170	15
GRAY CLAY		170	174	4
BROWN SAND	X	174	188	14

8. WELL CONSTRUCTION  
 Depth Drilled 188 Feet Depth Cased 188 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 3/4 Inches 0 Feet 50 Feet  
6 1/4 Inches 50 Feet 188 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FT (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	188

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 179 feet to 183 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 26 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. Contractor  
 Address P. O. BOX 888 Contractor  
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 11/21/1920 2004

Date started 9/29/1904 19\_\_\_\_  
 Date completed 10/23/1904 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIR LIFT	20		1 HR

RECEIVED  
 04 DEC - 7 AM 11:36  
 STATE ENGINEERS OFFICE