WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95332
Permit No.
Basin 101

NOTICE OF INTENT NO. 54912

1. OWNER BOB HAMMON CONSTRUCTION
MAILING ADDRESS 4340 SANTA FE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4340 SANTA FE N39
28.556 W 118.50.715

2. LOCATION SW 1/4 SE 1/4 Sec. 28 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | 008-401-74 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	15	14
BROWN CLAY		15	20	5
BROWN SAND		20	30	10
GRAY SAND/CLAYS		30	80	50
GRAY CLAYS		80	85	5
GRAY SANDS		85	100	15
GRAY SILTY/CLAY		100	120	20
GRAY SANDS		120	140	20
GRAY SANDS		140	152	12
GRAY CLAY		152	156	4
BROWN SAND	X	156	180	24

RECEIVED 04 DEC -7 AM 11:35 STATE ENGINEER'S OFFICE

Date started 11/18/1904 20M, 19__
Date completed 11/19/1904, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	10		1 HR

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 1/4	Inches	100	Feet	180	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	180

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 174 feet to 178 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 21'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 11/22/1920 2004

USE ADDITIONAL SHEETS IF NECESSARY