CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 75324
Permit No.
Basin 026

NOTICE OF INTENT NO. 53084

1. OWNER ANTELOPE CONSTRUCTION
MAILING ADDRESS
FERNLEY, NV 89408

ADDRESS AT WELL LOCATION 1610 DONNA WAY

2. LOCATION SW 1/4 SE 1/4 Sec. 22 T 20 N/S R 25 E LYON County
PERMIT NO. (Issued by Water Resources) 021-476-16 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | | 0 | 1 | |
| COBBLES/CLAY | | 1 | 15 | 14 |
| RED CLAY | | 15 | 30 | 15 |
| GRAVELS | | 30 | 80 | 50 |
| BROWN CLAY | | 80 | 100 | 20 |
| MC GRAVELS | X | 100 | 180 | 80 |
| SEALED WITH AQUAGUARD | | | | |

Date started 10/19/1904 2004, 19__
Date completed 10/25/1904, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR LIFT | 10 | | 1 HR |

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 3/4 | Inches | 0 | Feet | 100 | Feet |
| 6 1/4 | Inches | 100 | Feet | 180 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | 2 | 180 |

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 165 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 108' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 11/21/1920

USE ADDITIONAL SHEETS IF NECESSARY