COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95336
Permit No.
Basin 103

NOTICE OF INTENT NO. 53534

1. OWNER SCOTT SNELLING CONSTRUCTION
MAILING ADDRESS 318 SYDNEY LN
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 7445 CHEROKEE RD
DAYTON NV, 89403

2. LOCATION NE ¼ SW ¼ Sec 23 T 17 N R 22 E LYON County

PERMIT NO. (Issued by Water Resources) 15-326-21 (Permit No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY AND COBBLES		0	3	3
VOLCANIC GRAVELS		3	87	85
BROWN CLAY		87	96	9
COBBLES AND SANDS		96	128	32
BROWN CLAY		128	160	32
VOLCANIC FRACTURE	XXX	160	173	13
SOFT FRACTURED VOLCANIC SANDS	XXX	173	220	37

RECEIVED 04 DEC -7 AM 11:18 NEVADA DIVISION OF WATER RESOURCES

Date started 10/21, 20 04
Date completed 10/23, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	15	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	220 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	5/8	.188	0	220

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 220 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/24/04